

Exova Warringtonapt
Key Industrial Park
Fernside Road
Willenhall
West Midlands
WV13 3YA

T : +44 (0) 1902 722 122
F : +44 (0) 1902 727 242
E : willenhall@exova.com
W : www.exova.com



Testing. Advising. Assuring.

Report No: 189243/A

Test of:

Parallel Opener / Fixed Light
Window
ATB Secure



Tested to:

BS 6375-1:2009
Performance of windows & doors
Part 1: Weathertightness

For:

ATB Systems Ltd
Charter House
Brook Street
Lye
Nr Stourbridge
West Midlands
DY9 8SN



TEST CONCLUSIONS

Samples of:

Manufacturer ATB Systems Ltd
Product Parallel Opener / Fixed Light Window
Model ATB Secure

have been tested in accordance with: BS6375-1:2009

By Exova Warrington APT, a UKAS accredited Testing Laboratory (No. 0621) and EC Notified Body number (No, 1104)

At Key Industrial Park, Fernside Rd., Willenhall. West Midlands. WV13 3YA.

Results and comments as detailed below:

Clause No.	Description	Classification
4	Exposure category and classification	2000+
6	Test for air permeability (to EN1026)	CLASS 3
7	Test for watertightness (to EN1027)	CLASS 7A
8	Test for resistance to wind (to EN12211)	CLASS CE2200

No inferences can be made regarding performance against other requirements of this standard

Tests marked "N/A" are not applicable to the sample under test.

Tests marked "N/T" were not applied to the sample under test

AUTHORISATION

Tests performed by: Mark West, Assistant Operations Manager

Report issued by: Mark West, Assistant Operations Manager

Signed

Date 05/08/2010

For and on behalf of Exova Warrington APT

Report authorised by: Ian Keeling, Operations Manager

Signed

Date 05/08/2010

For and on behalf of Exova Warrington APT

Report issued: 05 August 2010



NOTE.

Tests marked "Not UKAS Accredited" are not covered by the Laboratory UKAS accreditation schedule.

Tests marked NT were not tested

Tests marked NA are not applicable to the product on test.

The laboratory has tested the product supplied by the client as sampled in accordance with their own requirements

Exova Warringtonapt is an EC Notified Body Number 1104

This report shall not be reproduced except in full, (and then only as permitted by copyright laws), without written approval from Exova warringtonapt