

Exova Warringtonapt
Key Industrial Park
Fernside Road
Willenhall
West Midlands
WV13 3YA

T : +44 (0) 1902 722 122
F : +44 (0) 1902 727 242
E : willenhall@exova.com
W : www.exova.com



Testing. Advising. Assuring.

Report No: 189243/B

Test of:

Parallel Opener / Fixed Light
Window
ATB Secure



Tested to:

WCL2 issue 2: August 2009
Burglar resistance of hinged,
pivoted, folding or sliding
doorsets, windows, curtain
walling, security grilles, garage
doors & shutters

For:

ATB Systems Ltd
Charter House
Brook Street
Lye
Nr Stourbridge
West Midlands
DY9 8SN



TEST CONCLUSIONS

Samples of:

Manufacturer ATB Systems Ltd
Product Parallel Opener / Fixed Light Window
Model ATB Secure

have been tested in accordance with: WCL2 issue 2: August 2009

By Exova Warrington APT, a UKAS accredited Testing Laboratory (No. 0621) and EC Notified Body number (No, 1104)

At Key Industrial Park, Fernside Rd., Willenhall. West Midlands. WV13 3YA.

Results and comments as detailed below:

Clause No.	Description	Classification
4	General Requirements	PASS
5	Pre-test to level BR1	PASS
6	Pre-test to level BR2	PASS
9	Pre-test to level BR3	FAIL
10	Main test to level BR3	FAIL
	Classification BR2	PASS

No inferences can be made regarding performance against other requirements of this standard

Tests marked "N/A" are not applicable to the sample under test.

Tests marked "N/T" were not applied to the sample under test

AUTHORISATION

Tests performed by: Mark West, Assistant Operations Manager

Report issued by: Mark West, Assistant Operations Manager

Signed 

Date 03/08/10

For and on behalf of Exova Warrington APT

Report authorised by: Ian Keeling, Operations Manager

Signed 

Date 03/08/10

For and on behalf of Exova Warrington APT

Report issued: 03 August 2010



NOTE.

Tests marked "Not UKAS Accredited" are not covered by the Laboratory UKAS accreditation schedule.

Tests marked NT were not tested

Tests marked NA are not applicable to the product on test.

The laboratory has tested the product supplied by the client as sampled in accordance with their own requirements

Exova Warringtonapt is an EC Notified Body Number 1104

This report shall not be reproduced except in full, (and then only as permitted by copyright laws), without written approval from Exova warringtonapt